

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Power supply for built-in use (DIN rail)

Name and address of the applicant

Traco Power Solutions Ltd.  
Whitemill Industrial Estate Wexford, White Mill Road,  
Y35 YH66, Ireland

Name and address of the manufacturer

Traco Power Solutions Ltd.  
Whitemill Industrial Estate Wexford, White Mill Road,  
Y35 YH66, Ireland

Name and address of the factory

Traco Power Solutions Ltd.  
Whitemill Industrial Estate Wexford, White Mill Road,  
Y35 YH66, Ireland*Note: When more than one factory, please report on page 2*☐ Additional Information on page 2

Ratings and principal characteristics

See page 3

Trademark / Brand (if any)

TRACO POWER

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See page 2

Additional information (if necessary may also  
be reported on page 2)Additionally evaluated to EN 61010-1:2010 + A1:2019  
and EN IEC 61010-2-201:2018; National Differences  
specified in the CB Test Report.☒ Additional Information on page 2A sample of the product was tested and found  
to be in conformity withIEC 61010-1:2010 + A1:2016  
IEC 61010-2-201: 2017As shown in the Test Report Ref. No. which  
forms part of this Certificate

T223-0812/20, T223-0813/20 (2020-12-11)

This CB Test Certificate is issued by the National Certification Body

SIQ Ljubljana, Mašera-Spasičeva ulica 10, SI-1000 Ljubljana, Slovenia  
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.siSIQ Ljubljana is accredited by Slovenian Accreditation with accreditation number CP-001 in the  
field of certification of products, processes and services.

Date: 2020-12-11

Signature: Bojan Pečavar



**Model / Type Ref.:**

TRACO POWER Model reference	Manufacturer Model reference
TBLC 06-105	006ECO181
TBLC 06-112	006ECO182
TBLC 06-124	006ECO184
TBLC 15-105	015ECO181
TBLC 15-112	015ECO182
TBLC 15-124	015ECO184
TBLC 25-105	025ECO181
TBLC 25-112	025ECO182
TBLC 25-124	025ECO184
TBLC 50-112	050ECO182
TBLC 50-124	050ECO184
TBLC 50-148	050ECO185
TBLC 75-112	075ECO182
TBLC 75-124	075ECO184
TBLC 90-112	090ECO182
TBLC 90-124	090ECO184
Each model may be followed by suffix "xx" where each "x" can be 'a-z' or '-0-9' for traceability only, no impact on safety"	

**Additional information (if necessary)**

Date: 2020-12-11

Signature: Bojan Pečavar



**Ratings and principal characteristics:****Input:**

TBLC 06-105: 100-240 Vac; 0,15 - 0,09 A; 50/60 Hz  
TBLC 06-112: 100-240 Vac; 0,14 - 0,08 A; 50/60 Hz  
TBLC 06-124: 100-240 Vac; 0,15 - 0,08 A; 50/60 Hz  
TBLC 15-105: 100-240 Vac; 0,3 - 0,17 A; 50/60 Hz  
TBLC 15-112: 100-240 Vac; 0,33 - 0,18 A; 50/60 Hz  
TBLC 15-124: 100-240 Vac; 0,35 - 0,2 A; 50/60 Hz  
TBLC 25-105: 100-240 Vac; 0,5 - 0,27 A; 50-60 Hz  
TBLC 25-112: 100-240 Vac; 0,6 - 0,33 A; 50/60 Hz  
TBLC 25-124: 100-240 Vac; 0,55 - 0,3 A; 50/60 Hz  
TBLC 50-112: 100-240 Vac; 1,1 - 0,6 A; 50/60 Hz  
TBLC 50-124: 100-240 Vac; 1,1 - 0,6 A; 50/60 Hz  
TBLC 50-148: 100-240 Vac; 1,1 - 0,6 A; 50/60 Hz  
TBLC 75-112: 100-240 Vac; 1,8 - 1,0 A; 50/60 Hz  
TBLC 75-124: 100-240 Vac; 1,8 - 1,0 A; 50/60 Hz  
TBLC 90-112: 100-240 Vac; 2,1 - 1,1 A; 50/60 Hz  
TBLC 90-124: 100-240 Vac; 2,1 - 1,1 A; 50/60 Hz

**Output:**

TBLC 06-105: 5 Vdc; 1,2 A; 6 W  
TBLC 06-112: 12 Vdc; 0,5 A; 6 W  
TBLC 06-124: 24 Vdc; 0,25 A; 6 W  
TBLC 15-105: 5 Vdc; 2,4 A; 12 W  
TBLC 15-112: 12 Vdc; 1,25 A; 15 W  
TBLC 15-124: 24 Vdc; 0,63 A; 15 W  
TBLC 25-105: 5 Vdc; 4 A; 20 W  
TBLC 25-112: 12 Vdc; 2 A; 24 W  
TBLC 25-124: 24 Vdc; 1,05 A; 25 W  
TBLC 50-112: 12 Vdc; 4 A; 48 W  
TBLC 50-124: 24 Vdc; 2,1 A; 50 W  
TBLC 50-148: 48 Vdc; 1,05 A; 50W  
TBLC 75-112: 12 Vdc; 6,0 A; 72 W  
TBLC 75-124: 24 Vdc; 3,1 A; 75 W  
TBLC 90-112: 12 Vdc; 7,5 A; 90 W  
TBLC 90-124: 24 Vdc; 3,75 A; 90 W

**Additional information (if necessary)**

Date: 2020-12-11

Signature: Bojan Pečavar

